

The University of Texas at Austin

Containment Drainage Report

- Instructions:**
1. Use one inspection form per containment area.
 2. Send completed inspection report to EHS Environmental Programs at EHS-Environmentalops@austin.utexas.edu
 3. A “No” response indicates follow-up action is required.
 4. Drain secondary containment within 24 hours of 1-inch rain or more.

Serial #/Building: _____ Date Drained: _____
 Responsible Department: _____ Inspector: _____
 Contact Phone Number: _____ Signature *: _____

- | | YES | NO | N/A |
|--|--------------------------|--------------------------|--------------------------|
| 1. There is NO evidence of oil on the water in the containment? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2. If NO evidence of oil leakage, containment drained to ground? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 3. Secondary containment is free of debris? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 4. Secondary containment valve is closed? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 5. Approximate gallons drained _____ | | | |

COMMENTS

Item #	Description of Follow-up Action Required	Date Completed

**By signing this form I certify that I have completed the inspection and the observations recorded are true and accurate to the best of my knowledge.*